

Thank you for participating in ADEM's Lead Testing in Child Care Facilities and Schools Program, a voluntary program funded by an EPA Grant under the Water Infrastructure Improvements for the Nation (WIIN) Act.

Our laboratory has analyzed the sample(s) submitted for your facility, and determined that none of them exceeded the Action Level of 0.02 mg/l of lead. The results are shown in the table below:

Oneonta Elementary School
 27605 State Hwy 75
 Oneonta, AL 35121-3228

Location	Result (mg/L)	Description	Comments
5th Grade Lobby Water Fountain	0.000428	Original	
Second Grade Water Fountain	0.000236	Original	
3rd Grade Water Fountain	0.000959	Original	
3rd Grade South Water Fountain	<MDL	Original	
Kindergarten Water Fountain	0.00248	Original	
1st Grade Water Fountain	0.000186	Original	
Middle School Water Fountain	0.00238	Original	
Teachers' Lounge	0.000408	Original	

*Any result listed as <MDL is below the detection limit of the test.

Oneonta High School
 27605 State Hwy 75
 Oneonta, AL 35121-3228

Location	Result (mg/L)	Description	Comments
H S Lobby Water Fountain	0.000546	Original	
Lunchroom Water Fountain	<MDL	Original	
Back Lobby Water Fountain	<MDL	Original	
Elementary Gym Water Fountain	<MDL	Original	

*Any result listed as <MDL is below the detection limit of the test.

FIRST BAPTIST CHURCH - ONEONTA
 300 - 3RD AVE. EAST
 ONEONTA, AL 35121

Location	Result (mg/L)	Description	Comments
Kitchen Sink	<MDL	Original	
Water Fountain	<MDL	Original	
Room E Sink	<MDL	Original	
Room H Sink	<MDL	Original	

*Any result listed as <MDL is below the detection limit of the test.

Appalachian School
 350 County Highway 12
 Oneonta, AL 35121-7112

Location	Result (mg/L)	Description	Comments
Blue Hall Water Fountain	<MDL	Original	
Kitchen Sink	0.000249	Original	
Indigo Hall Water Fountain	<MDL	Original	
Gym Water Fountain	<MDL	Original	
Red/Orange Halls Water Fountain	0.000226	Original	
Red Hall Water Fountain	<MDL	Original	
Teacher Lounge	0.000385	Original	
Green Hall Water Fountain	<MDL	Original	

*Any result listed as <MDL is below the detection limit of the test.

LESTER MEMORIAL UNITED METHODIST CHURCH
108 - 3RD AVENUE EAST
ONEONTA, AL 35121

Location	Result (mg/L)	Description	Comments
Room 101 Sink	<MDL	Original	
Room 105 Sink	<MDL	Original	
Room 107 Sink	<MDL	Original	
Room 110 Sink	<MDL	Original	
Kitchen Sink #1	<MDL	Original	
Kitchen Sink #2	<MDL	Original	
Kitchen Sink #3	<MDL	Original	
Water Fountain	<MDL	Original	

*Any result listed as <MDL is below the detection limit of the test.

KID'S CAMPUS
27550 STATE HWY 75 SUITE 106
ONEONTA, AL 35121

Location	Result (mg/L)	Description	Comments
Last Left Room	0.000372	Original	
1 Year Old Room	<MDL	Original	
Baby Room	<MDL	Original	
Kitchen Sink Big	<MDL	Original	

*Any result listed as <MDL is below the detection limit of the test.

RATCHFORD CHILD DEVELOPMENT HEAD START
600 JACKSON ST W
ONEONTA, AL 35121

Location	Result (mg/L)	Description	Comments
Kitchen Sink #1	0.00319	Original	
Kitchen Sink #2	<MDL	Original	
Kitchen Sink #3	0.00147	Original	
Kitchen Sink #4	<MDL	Original	

*Any result listed as <MDL is below the detection limit of the test.

These results will be posted on the [ADEM School Lead Webpage](#).